WTCI-379-P

...YORK, N.Y. 10022 · PLAZA 3-1733

JULIAN ROTH
ADMINISTRATION

ESTELLE BEAL
CONTROLLER

January 16, 1967

THE PORT OF NEW YORK AUTHORITY
RECEIVED
JAN 17 1967
WORLD TRADE DEPARTMENT
WORLD TRADE CENTER
PLANNING DIVISION

...Coordination

...York Authority

...York

Re: World Trade Center
Spray Fireproofing

...erb:

...request of the Port Authority, we have ac-...ed the suggestion of the structural engineers to ...ilize spray fireproofing throughout the tower in ...ieu of concrete.

We advise the use of an adhesive overspray on the Limpet in th return-air ceiling plenums to prevent flaking and detachment. Information and test results of this material from the Armstrong Corporation are enclosed. This data also suggests the possibility that the overspray on the Limpet can be used instead of cementitious spray fireproofing in return air shafts, elevator shafts and mechanical spaces.

Unless you direct us to the contrary, we will specify the overspray for all Limpet surfaces and as an alternate to the cementitious spray.

Cordially,

EMERY ROTH & SONS

BY _____
JOSEPH H. SOLOMON

JHS:mc

cc: L. Robertson/WTCJ
A. Schreier/NYA
D. Fernandez/ERS

PLAINTIFF'S EXHIBIT
PX-461

...STUTZ & A. BERNARD ROSSLER, A.I.A.